

Message

From: Hanchett, James (DPH) [/O=COMMONWEALTH OF MASSACHUSETTS/OU=MASSMAIL-01/CN=RECIPIENTS/CN=JAMES.HANCHETT]
Sent: 2/23/2012 6:40:48 PM
To: 'Lobik Stephen' [slobik@facil.umass.edu]
Subject: RE: AC/Heating Unit

Hi Steve,
UMass adjusted the steam pressure and the noise is gone for now. I will let you know if it returns.

Thanks,

Jim

-----Original Message-----

From: Lobik Stephen [mailto:slobik@facil.umass.edu]
Sent: Wednesday, February 22, 2012 10:17 AM
To: Hanchett, James (DPH)
Subject: Re: AC/Heating Unit

Jim I am away this week did umass say they couldn't fix it?

Sent from my iPhone

On Feb 21, 2012, at 7:37 AM, "Hanchett, James (DPH)"
<james.hanchett@state.ma.us<mailto:james.hanchett@state.ma.us>> wrote:

Hi Steve,
We are having a problem with the heating unit in Morrill I, Room N251. Is it still under warrantee? UMass has tried to fix it but they can't.

Jim Hanchett

Amherst Drug Lab

Room N251 Morrill I

637 North Pleasant Street

Amherst, MA 01003

Phone 413-545-2607

Fax 413-545-2608

Cell [REDACTED]